

- Alt 4 (dual conveyance) – ELT

The same system demands and facilities as described in the NAA-ELT with the following primary changes: three proposed North Delta Diversion (NDD) intakes of 3,000 cfs each; NDD bypass flow requirements; additional positive OMR flow requirements and elimination of the San Joaquin River I/E ratio and the export restrictions during VAMP; modification to the Freemont Weir to allow additional seasonal inundation and fish passage; modified Delta outflow requirements in the spring and/or fall (defined in the Decision Tree discussed below); movement of the Emmaton salinity standard; redefinition of the EI ratio; and removal of current permit limitations for the south Delta export facilities. Set within the ELT environment.

- Alt 4 (dual conveyance) – LLT

The same as the previous Scenario except established in the LLT environment.

The BDCP contemplates a dual conveyance system that would move water through the Delta's interior or around the Delta through an isolated conveyance facility. The BDCP CalSim II files contained a set of studies evaluating the projected operation of a specific version of such a facility. The Alternative was imposed on two baselines: the NAA-ELT scenario and the NAA-LLT scenario.

The changes (benefits or impacts) of the operation due to Alt 4 are highly dependent upon the assumed operation of not only the BDCP facilities and the changed regulatory requirements associated with those facilities, but also by the assumed integrated operation of the CVP and SWP facilities. The modeling of the NAA Scenarios introduced a significant change in operating protocols suggested primarily for reaction to climate change. We consider the extent of the reaction not necessarily representing a likely outcome, and thus have little confidence that the NAA baselines are a "best" (or even valid) representation of a baseline from which to compare an action Alternative. However, a comparison review of the Alternative to the NAA baselines illuminates operational issues in the BDCP modeling and provides insight as to where benefits or impacts may occur as additional studies are provided.

Since the effects of climate changes are more severe in the LLT than in the ELT, this review focuses on the ELT modeling because the results are less skewed by the climate change assumptions and problems.

BDCP's Alternative 4 has four possible sets of operational criteria, termed the Decision Tree, that differ based on the "X2" standards⁷ that they contemplate:

- Low Outflow Scenario (LOS), otherwise known as operational scenario H1, assumes existing spring X2 standard and the removal of the existing fall X2 standard;
- High Outflow Scenario (HOS), otherwise known as H4, contemplates the existing fall X2 standard and providing additional outflow during the spring;
- Evaluated Starting Operations (ESO), otherwise known as H3, assumes continuation of the existing X2 spring and fall standards;
- Enhanced spring outflow only (not evaluated in the December 2013 Draft BDCP), scenario H2, assumes additional spring outflow and no fall X2 standards.

While it is not entirely clear how the Decision Tree would work in practice, the general concept is that the prior to operation of the new facility, implementing authorities would select the appropriate Scenario (from amongst the four choices) based on their evaluation of targeted research and studies to be conducted during planning and construction of the facility.

⁷ X2 is a salinity standard that requires outflows sufficient to attain a certain level of salinity at designated locations in the Delta at certain times of year.

For our analysis, we reviewed the HOS (or H4) scenario because the BDCP⁸ indicates that the initial permit will include HOS operations that may be later modified at the conclusion of the targeted research studies. The HOS includes the existing fall X2 requirements but adds additional outflow requirements in the spring. We reviewed the model code and discussed the operations with DWR and Reclamation, who acknowledged that although the SWP was bearing the majority of the responsibility for meeting the additional spring outflow in the modeling, the responsibility would need to be shared with the CVP⁹. In subsequent discussions, DWR and Reclamation have suggested that the additional water may be purchased from other water users. However, the actual source of water for the additional outflow has not been defined. Since the BDCP modeling assumes that SWP bears the majority of the responsibility for meeting the additional outflow, yet this is not how the project will be operated in reality, our review of the BDCP modeling results for HOS is limited to the evaluation of how the SWP reservoir releases on the Feather River translate into changes in Delta outflow and exports.

Our remaining analysis examines the ESO (or H3) scenario (labeled Alt 4-ELT or Alt 4-LLT in this section) because it employs the same X2 standards as are implemented in the No Action Alternatives NAA-ELT and NAA-LLT. This allows us to focus our analysis on the effects of the BDCP operations independent of the possible change in the X2 standard.

High Outflow Scenario (HOS or H4) Results

In Alt 4-ELT H4 Feather River flows during wetter years are increased more than 3,000 cfs in April and May and then decreased in most year types during July and August, while September flow is only decreased in wetter years. Figure 14 shows average monthly change in Feather River flow by water year type. Accompanying the changes in Feather River flow are changes in Oroville Reservoir storage levels, Figure 15 contains average monthly changes in Oroville storage. Alt4-ELT H4 end of June storage in Oroville during wetter years is about 480 TAF lower than the NAA-ELT while critical year storage is about 400 TAF higher. Counter to the reduction in Oroville storage, CVP average upstream carryover storage increases about 80 TAF and critical year increases by 380 TAF. Figure 16 contains average monthly changes in Delta outflow, increases in Feather River spring time flows are generally not used to increase Delta outflow, but are allowed to support increases in Delta exports.

Figure 17 displays changes in average monthly Delta exports, there are increases when diverting higher upstream spring releases in wetter years, while there are decreases during summer months in most years. Figure 18 contains an average annual summary of project deliveries, total CVP deliveries increase by about 70 TAF while SWP deliveries decrease by about 100 TAF. Dryer year SWP deliveries decrease by 250 to 400 TAF, while wet year deliveries increase by 200 TAF. Total CVP deliveries increase in wetter years by exporting increased releases from Oroville.

The overall effect of the HOS appears to be increases in Oroville releases that support both CVP and SWP exports in wetter years, with modest increases in Delta outflow. There is also a decrease in SWP reliability through large delivery reductions in dryer years accompanied by Oroville storage increases. In addition to increases in dry and critical year storage in Oroville, total CVP dry and critical year carryover increases by 100 TAF and 380 TAF respectively with negligible reductions in wetter years types.

⁸ Draft BDCP, Chapter 3, Section 3.4.1.4.4

⁹ August 7, 2013 meeting with DWR, Reclamation, and CH2M HILL

CVP and SWP obligation for providing flow to satisfy Delta outflow requirements is described in the Coordinated Operations Agreement (COA). Because the CVP and SWP share responsibility for meeting required Delta outflow based on specific sharing agreement, it doesn't seem reasonable that CVP water supplies would increase while SWP water supplies decrease under this Alternative. The manner in which this alternative is modeled is inconsistent with existing agreements and operating criteria. If the increases in outflow were met based on COA, there would likely be reductions in Shasta and Folsom storage that may cause adverse environmental impacts.

Figure 14. Changes in Feather River Flow, Alt 4 H4 ELT minus NAA-ELT




Figure 15. Changes in Oroville Storage, Alt 4 H4 ELT minus NAA-ELT




Figure 16. Changes in Delta Outflow, Alt 4 H4 ELT minus NAA-ELT




Figure 17. Changes in Delta Export, Alt 4 H4 ELT minus NAA-ELT





Figure 18. Changes in CVP and SWP Deliveries, Alt 4 H4 ELT minus NAA-ELT




Evaluated Starting Operations (ESO or H3) Results

North Delta Diversion Intakes

Sacramento River flow below the North Delta Diversion (NDD) must be maintained above the specified bypass flow requirement, therefore the NDD rates are limited to the Sacramento River flow above the bypass requirement. Due to an error in CalSim II that specifies an unintended additional bypass requirement, modeling performed for the BDCP EIRS often bypasses more Sacramento River flow than is specified in the BDCP project description. This error has been fixed in the most recent public releases of CalSim II, but BDCP modeling has not been updated to reflect these fixes. Figure 19 contains exceedance probability plots showing the Sacramento River required bypass, Sacramento River bypass flow, NDD, and excess Sacramento River flow to the Delta as modeling for BDCP. As can be seen in Figure 19, the bypass flow is always above the bypass requirement in July and August. The BDCP version of CalSim sets a requirement for Sacramento River inflow to the Delta needed to satisfy all Delta flow, quality, and export requirements, this requirement should be removed when modeling the NDD.


Figure 19. NDD, Bypass Requirement, Bypass Flow, and Excess Sacramento R. flow for Alt 4-ELT



CVP/SWP Exports

Overall the Alt 4 will increase exports compared to the NAA-ELT, with the majority of the increased exports realized by the SWP. Figure 20 illustrates a comparison between the NAA-ELT and Alt 4-ELT of CVP and SWP exports. On average, total combined exports under Alt 4-ELT are projected to increase by 537 TAF from 4.73 MAF to 5.26 MAF compared to the NAA-ELT.

Figure 20. Change in CVP (Jones) and SWP (Banks) Exports (Alt 4-ELT minus NAA-ELT)



With the addition of the North Delta Diversion facility, the water exported dramatically shifts from South Delta diversions to North Delta diversions. Figure 21 illustrates the change in routing of South of Delta exports under Alt 4 compared to the NAA-ELT. On average, export through the South Delta facility are projected to decrease by 2.1 MAF and the North Delta diversions will export 2.6 MAF which includes the 2.1 MAF shifted from the South Delta facility plus the additional 537 TAF of increased exports.

Figure 21. Change in Conveyance Source of Exports (Alt 4-ELT minus NAA-ELT)





Figure 22 contains figures for July, August, and September for Alt 4-ELT that plot NDD against SDD. In the months of July to September SDD are occasionally very high, exceeding 14,000 cfs in July, with minimal NDD. This occurs due to outdated model code that imposes an instream flow requirement in Sacramento River flow below Hood in excess of the bypass criteria prescribed in the BDCP. There are numerous occurrences when bypass flows prescribed in the BDCP are exceeded and SDD are higher than expected. On the other hand, there are also many times when NDD are above minimum pumping levels and SDD are below the BDCP prescribed 3,000 cfs threshold indicated by the green line in Figure 22. Alt 4-ELT North Delta Diversion Versus South Delta Diversion for July,

August, and September. For unknown reasons, the model code requiring SDD to be greater than 3,000 cfs before NDDs occur from July through September is deactivated in the BDCP modeling of this Alternative.


Figure 22. Alt 4-ELT North Delta Diversion Versus South Delta Diversion for July, August, and September



South Delta Diversion at Banks is not limited to existing permit capacity of 6,680 cfs and pumping may reach full capacity of 10,300 cfs in July, August, and September. Figure 23 contains exceedance probability charts of South

Delta Diversion at Banks for July, August, and September. The chart for July shows SDD at Banks exceeding existing permit capacity 20% of years, in August this occurs in about 7% of years. There are South Delta diversions at Banks 25% of the time in September while diversions from the Sacramento River may range from 2,500 cfs to 7,500 cfs.

Figure 23. South Delta Diversion at Banks




Generally exports increase during winter and spring months due to the ability to avoid fishery concerns by diverting at the North Delta rather than South Delta.

Delta Outflow

Figure 24 illustrates a comparison of Delta outflow between the NAA-ELT and Alt 4-ELT. Decreases in Delta outflow are the result of the CVP and SWP ability to increase Delta exports in Alt 4-ELT. The apparent increase in Delta outflow in October is partially due to additional export restrictions through Old and Middle River flow requirements. However, the increase in October Delta outflow is also due to an unrealistic operation of the Delta Cross Channel. The additional export restrictions cause the flow standards imposed at Rio Vista to be the controlling point in CVP and SWP operations; the water quality standards are all being met and do not require flows above the amount needed to satisfy the Rio Vista standard. Meeting the Rio Vista flow standards without closing the Delta Cross Channel gate results in releasing more water from upstream reservoirs than would otherwise be necessary. This occurs because a certain amount of the water released to meet the Rio Vista flow standards would flow into the Central Delta at location of the Delta Cross Channel gate. This water would not make it to Rio Vista and therefore would not be counted towards meeting the Rio Vista flow standards. However, due to the BDCP model's assumed restrictions on exports at this time, this water could not be pumped from the South Delta facilities and thus ends up as "extra" Delta outflow. By closing the Delta Cross Channel gate, the operators would assure that all of the water released to meet the Rio Vista flow standards would be counted towards those standards. The BDCP model's assumptions that the Delta Cross Channel gate would not be closed are not practical or a sensible operation as the operators confirmed they would close the gate during these conditions to avoid the unnecessary loss of water supplies (as was done in October and November 2013). The assumption in the BDCP model to maintain the gate in the open position causes it to overstate the amount of Delta outflow.

Figure 24. Delta Outflow Change (Alt 4-ELT minus NAA-ELT)



CVP/SWP Reservoir Carryover Storage

CVP/SWP reservoir operating criteria in the Alt4-ELT scenario differs from the NAA-ELT scenario. This difference is primarily driven by changes in both CVP and SWP San Luis Reservoir target storage. CalSim II balances upstream Sacramento Basin CVP and SWP reservoirs with storage in San Luis Reservoir by setting target storage levels in San Luis Reservoir. CalSim II will release water from upstream reservoirs to meet target levels in San Luis Reservoir and the target storage will be met as long as there is capacity to convey water and water is available in upstream reservoirs. In Alt 4 the San Luis Reservoir target storage is set very high in the spring and early summer months, and then reduced in August and set to San Luis Reservoir dead pool from September through December. This change in San Luis target storage relative to the NAA causes upstream reservoirs to be drawn down from June through August and then recuperate storage relative to the NAA by cutting releases in September; Alt 4 upstream storage then remains close to the NAA during fall months. These operational criteria cause changes in upstream

cold water pool management and affect several resource areas. Figure 25, Figure 26, Figure 27, and Figure 28 contain exceedance charts for carryover storage and average monthly changes in storage by Sacramento Valley Water Year Type for North of Delta CVP and SWP reservoirs.

San Luis Reservoir Operations

In addition to changes in upstream storage conditions, changes in San Luis Reservoir target storage cause San Luis Reservoir storage to reach dead pool in many years with subsequent SOD delivery shortages. Although some delivery shortages are due to California Aqueduct capacity constraints, the largest annual delivery shortages are a result of inappropriately low target storage levels. Average annual Table A shortages due to artificially low San Luis reservoir storage levels increased from 3 TAF in the NAA-ELT scenario to 35 TAF in the Alt4-ELT scenario. (Shortages due only to a lack of South of Delta conveyance capacity were not included in these averages.) Such shortages occurred in 2% of simulated years in the NAA-ELT scenario and 23% of years in the Alt4-ELT scenario. In addition to the inability to satisfy Table A allocations, low storage levels cause loss of SWP contractors' Article 56 water stored in San Luis Reservoir. Average annual Article 56 shortages were 43 TAF in the Alt4-ELT scenario because of low San Luis storage and 5 TAF in the NAA-ELT scenario. Low San Luis storage causes Article 56 shortages in 27% of simulated years in the Alt4-ELT scenario as compared to 5% of simulated years in the NAA-ELT. Another consequence of low storage levels in San Luis Reservoir is a shift in water supply benefits from Article 21 to Table A. As seen in Figure 29 and Figure 30 San Luis Reservoir storage fills more regularly in the Alt 4-ELT scenario, but is exercised to a lower point more often.

Figure 25. Trinity Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 26. Shasta Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 27. Oroville Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 28. Folsom Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 29. Federal Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT)





Figure 30. State Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT)



CVP Water Supply

The changes in water supply to CVP customers, based on customer type and water year type is shown in Table 3. Alt 4-ELT shows an average increase of approximately 109,000 AF of delivery accruing to CVP customers with CVP SOD agricultural contractors receiving most of the benefit. Changes in Sacramento River Settlement contract deliveries are not an anticipated benefit of the BDCP, increases in these deliveries in Alt 4-ELT relative to the NAA-ELT are due to the shortages in the NAA-ELT from climate change that are reduced in Alt 4-ELT. Although the BDCP modeling demonstrates minor benefits to NOD CVP service contractors, this increase is not an anticipated benefit of the BDCP.


Consistent with modeling for the NAA-ELT Scenario, San Joaquin River Exchange Contractors receive full deliveries in accordance with contract provisions. Figure 31 compares CVP Service Contract delivery of Alt 4-ELT to the NAA-ELT Scenario. Increases in delivery generally occur in below and above normal years.

Table 3. CVP Delivery Summary (Alt 4-ELT and NAA-ELT)

NAA-ELT (1,000 AF)										
	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	187	796	852	201	112	86	271	1846	2321	2215
W	309	1364	875	236	134	90	281	1856	2491	2837
AN	246	908	802	214	110	83	257	1716	2258	2246
BN	146	596	875	198	108	92	281	1899	2335	2044
D	95	440	864	175	100	90	277	1890	2250	1864
C	29	152	741	140	79	64	223	1674	1908	1376

Difference: Alt4-ELT minus NAA-ELT (1,000 AF)										
	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	8	90	0	4	4	1	0	3	15	94
W	1	68	0	1	3	2	1	-2	1	72
AN	14	199	0	3	12	1	0	-1	17	211
BN	17	153	0	5	4	0	0	0	22	158
D	10	48	0	5	2	1	-1	-1	15	49
C	3	6	0	5	2	-1	2	26	33	12

Figure 31. CVP Service Contract Deliveries (Alt 4-ELT and NAA-ELT)



SWP Water Supply


Similar in nature, but larger in magnitude are changes in SWP deliveries. Figure 32 and Table 4 illustrate the benefits of Alt 4-ELT in comparison to the NAA-ELT Scenario. These studies show an increase in average annual SWP SOD deliveries of approximately 408,000 AF, but a reduction in critical year deliveries of approximately 177,000 AF. There is an overall reduction in Article 56 deliveries. Typically in modeling and in actual SWP operations, increases in Table A correspond with increases in Article 56. The reason that Article 56 deliveries decrease overall is that insufficient quantities of water are carried over in San Luis and Article 56 contractors are subsequently shorted. SWP delivery increase is slightly less than increases in Banks export because there is increased wheeling for the Cross Valley Canal contractors with BDCP.

Table 4. SWP Delivery Summary (Alt 4-ELT and NAA-ELT)

NAA-ELT (1,000 AF)				
	Table A	Art. 21	Art. 56	Total
All Years	2425	52	90	2567
W	3112	79	112	3303
AN	2467	34	57	2559
BN	2515	48	109	2673
D	2033	43	88	2165
C	1172	28	47	1246

Difference: Alt4-ELT minus NAA ELT (1,000 AF)				
	Table A	Art. 21	Art. 56	Total
All Years	339	75	-6	408
W	587	159	5	751
AN	728	99	-24	803
BN	525	44	2	571
D	-120	19	-10	-111
C	-146	-19	-12	-177

Figure 32. SWP Contract Deliveries (Alt 4-ELT and NAA-ELT)



Freemont Weir Modifications and Yolo Bypass Inundation

A component of the BDCP Alternative 4 is a modification to the Freemont Weir to allow water to flow into the Yolo Bypass when the Sacramento River is at lower flow than is currently needed. Currently, the Sacramento River does not flow over the Freemont Weir until flow reaches about 56,000 cfs. With the proposed modification Sacramento River flow may enter the Yolo Bypass at much lower flow levels. Figure 33 and Figure 34 contains charts that compare Freemont Weir flow into the Yolo Bypass to Sacramento River flow at the weir, Figure 33 show this relationship for the NAA-ELT and Figure 34 shows this same relationship for Alt 4-ELT.

Although CalSim II is a monthly time-step model, it contains an algorithm that estimates daily flow. Therefore, average monthly flows displayed in Figure 33 shows Sacramento River entering the Yolo Bypass at flow levels less than 56,000 cfs, when this occurs water is flowing over the Freemont Weir for a portion of the month. There is a 100 cfs minimum flow diversion from the Sacramento River diversion to the Yolo Bypass from September through June in Alt 4-ELT.

Figure 35 and Figure 36 contains average monthly flow from the Sacramento River over the Freemont Weir to the Yolo Bypass for the NAA-ELT (Figure 35), average monthly difference between Alt 4-ELT and NAA-ELT (Figure 36), and the annual average difference between Alt 4-ELT and NAA-ELT (Figure 37). In the NAA-ELT scenario flow over the Freemont Weir generally occurs in wet years, this flow is extended to all year types and all months except July and August in Alt 4-ELT. The average annual increase in flow is about 430 TAF.

Figure 33. Fremont Weir vs. Sacramento River NAA-ELT




Figure 34. Fremont Weir vs. Sacramento River Alt 4-ELT




Figure 35. Average Fremont Weir Flow to Bypass by Water Year Type NAA-ELT




Figure 36. Average Fremont Weir Flow to Bypass by Water Year Alt 4 ELT minus NAA-ELT






Figure 37. Annual Change in Fremont Weir Flow to Bypass Alt 4-ELT minus NAA-ELT



Sacramento River Temperature

Figure 38 contains exceedance probability plots of Sacramento River temperature at Bend Bridge for the NAA-ELT and Alt 4-ELT. For the months of April through July modeling shows few changes in upper Sacramento River water temperature. The Alt 4-ELT scenario shows temperature increases in August relative to the NAA-ELT. In about 75% of years modeling shows about 0.5°F increase in Alt 4-ELT relative to the NAA-ELT. The temperature models will meet inputted target temperatures until Shasta Lake cold water is depleted, this typically occurs in September. This is the likely reason temperature increases in modeling tend to occur in September.

Figure 38. Sacramento River Temperature at Bend Bridge NAA-ELT and Alt 4-ELT



Conclusions regarding CalSim II modeling of BDCP Alternative 4

BDCP's "High Outflow Scenario" is not sufficiently defined for analysis.

The High Outflow Scenario (HOS) requires additional water (Delta outflow) during certain periods in the spring. The BDCP places most of the responsibility for meeting this new requirement on the SWP. However, under the Coordinated Operations Agreement ("the COA"), when one project – either the CVP or the SWP – assumes sole responsibility for meeting a regulatory standard that imposes a water cost, the CVP and the SWP water allocations are adjusted to share the burden and avoid a windfall to the water users who have not "paid" their share. Yet, the BDCP modeling does not adjust operations to pay back the COA debt accrued to the SWP due to the additional Delta outflow requirements.

Furthermore, after consultation with DWR and Reclamation operators and managers, we conclude that there is no apparent source of CVP or SWP water to satisfy the increased outflow requirements and pay back the COA debt without depleting upstream storage. Recent public discussions of the High Outflow Scenario indicate that additional water to satisfy the increased spring outflow requirement will need to be obtained from water transfers from upstream water users to avoid depleting cold water pools in upstream reservoirs. However, this approach is unrealistic: during most of the spring time period when the flows are proposed to be increased, agricultural water users are not irrigating. This means that there is not sufficient water available to meet the increased flow requirements without taking stored water from the reservoirs, which would potentially impact salmonids on the Sacramento River system.

Simulated operation of BDCP's dual conveyance, coordinating proposed North Delta diversion facilities with existing south Delta diversion facilities, is inconsistent with the project description.

The Draft Plan and associated Draft EIR/EIS specify criteria for how much flow can be diverted by the new north Delta diversion (NDD) facilities and specify when to preferentially use the NDD facilities or the existing south Delta diversion (SDD) facilities. However, the BDCP modeling contains an erroneous constraint that is preventing the NDD facilities from taking as much water as is described in the project description. Although this error has been fixed by DWR and Reclamation in more recent versions of the model, it remains a problem in the BDCP models. Additionally, the BDCP modeling does not reflect summertime operations of the South Delta intakes that are described in the Draft EIR/EIS as a feature of the BDCP project intended to prevent water quality degradation in the south Delta. The net effect of these two issues is that the BDCP modeling significantly underestimates the amount of water diverted from the new North Delta facilities and overestimates the amount of water diverted from the South Delta.

BDCP modeling contains numerous coding and data issues that skew the analysis and conflict with actual real-time operational objectives and constraints

Operational logic is coded into the CalSim II model to simulate how DWR and Reclamation would operate the system under circumstances for which there are no regulatory or otherwise definitive rules. This attempt to specify (i.e., code) the logic sequence and relative weighting such that a computer can simulate "expert judgment" of the human operators is a critical element to the CalSim II model. In the BDCP model, some of the operational criteria for existing facilities such as the Delta Cross Channel and San Luis Reservoir are inconsistent with real-world conditions.

3 INDEPENDENT MODELING

This effort originally stemmed from reviews of BDCP modeling where we found that BDCP modeling does not provide adequate information to determine how BDCP may affect the system. There are three basic reasons why we cannot determine how the BDCP will affect water operations: 1) NAAs do not depict reasonable operations due to climate change assumptions, 2) operating criteria used in the BDCP Alternative 4 result in unrealistic operations, and 3) updates to CalSim II since the BDCP modeling was performed almost 4 years ago will likely alter model results.

The first phase of this independent modeling effort was development of updated Existing and Future Condition Baselines that are acceptable to all parties involved in this process, which included a coordinated effort with Reclamation and DWR. The second phase of this effort was analysis of BDCP Alternatives using updated CalSim II baselines.

Independent modeling was performed by imposing various components of the BDCP Alternative 4 on the Future Conditions Baseline. Not only is this the typical method of performing CEQA and NEPA analysis, but it demonstrates how proposed projects may alter the current operations within a generally understood contemporary setting.

3.1 Changes to CalSim II Assumptions

Revisions approved by DWR and Reclamation for the 2013 baseline

DWR and Reclamation provided CalSim II models used for the 2013 SWP Delivery Reliability Report (DRR) for use in this independent modeling effort. Changes to these models were made for this effort and provided to DWR and Reclamation, many of these changes have since been incorporated into DWR and Reclamation's model and others are under review.

The CalSim II model used for the 2013 SWP DRR is located on DWR's web site at:

<http://baydeltaoffice.water.ca.gov/modeling/hydrology/CalSim/Downloads/CalSimDownloads/CalSim-IIStudies/SWPReliability2013/index.cfm>. Documentation for this model is described in the report titled: "Draft Technical Addendum to the State Water Project Delivery Reliability Report 2013", also located on DWR's web site at: <http://baydeltaoffice.water.ca.gov/swpreliability/>. Key modeling assumptions used for this effort are consistent with the 2013 SWP DRR and are listed in Table 4 of the Technical Addendum.

CalSim II is continuously being worked on and improved to better represent CVP and SWP operations and fix known problems. The Technical Addendum to the 2013 SWP DRR contains a description of updates and fixes that have occurred since modeling was performed for the BDCP Draft EIRS. Among these changes and fixes are key items that directly affect operation of facilities proposed in BDCP Alternative 4, these items are described on page 4 of 2013 SWP DRR Technical Addendum. Key among these fixes is the correction of the Sacramento River flow requirement for Delta inflow that causes NDD bypass to exceed requirements.

A key component of this independent modeling effort is the development of an acceptable CalSim II Future No-Action (FNA) model scenario. The purpose for developing the FNA Scenario is to produce an operational scenario that is realistic enough to understand how changes proposed in the BDCP will affect operations. The process of developing the FNA involved research and development of CalSim II model updates and several meetings with Reclamation and DWR modeling and operations staff. In addition to changes in the FNA Scenario, CalSim II was updated to better reflect operation of the NDD, CVP and SWP reservoir balancing, DCC gate operations, and CVP/SWP water supply allocations.

Additional Revisions to CalSim II Assumptions

The following changes were made to the 2013 SWP DRR version of CalSim II for this effort:

- San Joaquin River Basin
 - Turned off San Joaquin River Restoration Program (SJRRP) The SJRRP will cause a change to San Joaquin River inflow to the Delta not associated with the BDCP. To avoid adding complications to the identification of BDCP export benefits the SJRRP was not incorporated into the analysis.
 - Tuolumne: updated time-series, lookup tables, and wresl code
 - Turned off SJRA (VAMP) releases
- Updated Folsom flood diagram
- Rice decomposition demand diversions from Feather River
- Dynamic EBMUD diversion at Freeport
- SEP1933 correction to daily disaggregated minimum flow requirements at Wilkins Slough and Red Bluff
- CVP M&I demands are updated to reflect assumptions used by Reclamation
- Yuba Accord Transfer
- Los Vaqueros Reservoir capacity

San Joaquin River Basin

BDCP modeling depicted San Joaquin River Basin operations generally consistent with the actions, programs and protocols in place at the time of NOI/NOP issuance. Some of those conditions are now not representative of current development or operations. With the exception of the assumption for the SJRRP, the independent modeling has revised San Joaquin River Basin operations to reflect more contemporary LOD assumptions. In future level analyses the independent modeling similarly assumes no SJRRP, but only for analysis simplicity concerning BDCP export benefits. Additional analyses may be useful in understanding effects of collectively implementing the BDCP and SJRRP.

The San Joaquin River Basin (SJR) is depicted for current conditions, primarily affected by the operations of the Stanislaus, Tuolumne, Merced, and upper San Joaquin River tributaries. The upper San Joaquin River is currently modeled in a “pre-” SJRRP condition, consistent with the 2005 CalSim version. The FNA Scenario also models the upper San Joaquin River without the SJRRP. The SJR depicts near-term operations including SWRCB D-1641 flow and water quality requirements at Vernalis met when hydrologically possible with New Melones operations. The Vernalis flow objective is set by SWRCB D-1641 February-June base flow requirements. There are no pulse flow requirements during April and May, and there is no acquired flow such as VAMP or Merced water. D1641 Vernalis water quality requirements are set at 950/650 EC to provide an operational buffer for the requirement. New Melones is operated to provide RPA Appendix 2E flows as fishery releases and maintains the DO objective in the Stanislaus River through a flow surrogate. Stanislaus River water right holders (OID/SSJID) are provided deliveries up to land use requirements as occasionally limited due to operation agreement (formula). CVP Stanislaus River contractors are provided allocations up to 155 TAF per year in accordance with proposed 3-level plan based on the New Melones Index (NMI). For modeling purposes during the worst drought sequence periods, CVP Stanislaus River contractors and OID/SSJID diversions are additionally cut to maintain New Melones Reservoir storage no lower than 80 TAF. Merced River is operated for Federal Energy Regulatory Commission (FERC) and Davis-Grunsky requirements, and provides October flows as a condition of Merced ID’s water rights. The Tuolumne River is operated to its current FERC requirements and current water use needs and has been updated to recent conditions.

Folsom Lake Flood Control Diagram

During wetter years, inflow to Folsom Lake is sufficient to keep the reservoir full while satisfying all demands downstream. When this condition occurs in actual operations, operators increase releases during summer months to maintain higher instream flows and prevent large releases in the fall to evacuate Folsom to satisfy flood control storage requirements. To prevent the model from keeping the reservoir full going into the fall months and then making large releases to comply with flood control storage requirements, the maximum allowable storage during summer months is ramped from full storage in June to flood control levels in the fall. Although this is a common modeling tool, Folsom storage level for the end of September was set too low in the SWP DRR model causing unnecessary releases and resulting in Folsom storage being lower than desired. An adjustment was made to achieve a more realistic summer drawdown for Folsom.

Feather River Rice Decomposition Demand

Demand for rice straw decomposition (decomp) water from Thermalito Afterbay was added to the model and updated to reflect historical diversion from Thermalito in the October through January period. There are approximately 110,000 acres of rice in the Feather River Service Area irrigated primarily with water diverted from Thermalito Afterbay. Although decomp water demand for the Sacramento River has been included in CalSim II since about 2006, this demand has been absent for the Feather River. Inclusion of decomp demand in the version of CalSim II used for this effort results in an increase in Feather River diversion in fall months of about 160,000 AF.

Dynamic EBMUD Diversion at Freeport

Previously the EBMUD operation was pre-determined and input to CalSim II as a time-series. The below criteria was implemented in CalSim II model code to achieve a dynamic representation of EBMUD diversion from the Sacramento River at Freeport.

The EBMUD water service contract is unique. EBMUD's total system storage must be forecast to be below 500 TAF on October 1 for CVP water to be available under the EBMUD contract. In years when this occurs, we assume EBMUD will take the minimum of 65 TAF of CVP water or their CVP allocation (133 TAF * CVP M&I allocations) in the first and second years of any multi-year period when CVP water is available under their contract. In the third year, EBMUD would be limited to 35 TAF of CVP water (assuming diversion of 65 TAF in years one and two) because their contract limits cumulative CVP water over three consecutive years to 165 TAF. The 65, 65, 35 TAF annual diversion pattern then repeats if water is available for four or more consecutive years under the EBMUD contract.

Wilkins Slough Minimum Flow Requirement

Wilkins Slough minimum flow requirements, C129_MIF, includes an adjustment for daily operations based on work with the Sacramento River Daily Operations Model (SRDOM). The flow adjustment for daily flows for September 1933 in the state variable input file appeared unreasonable in the previous model. The flow adjustment in this month was approximately 1,860 cfs and was requiring release of approximately 100 TAF out of Shasta. Review of the entire time-series of daily adjustments showed the adjustment in this month was an order of magnitude greater than in any other September in the simulation period. The year 1933 is a critically dry year, and the third of four consecutive Shasta Critical years. Historical precipitation records from the consumptive use models for the Sacramento Valley, which serves as the basis of much of the CalSim hydrology, were reviewed to ensure there was no unusual precipitation in this month that may create variations in daily flows. It was determined that this daily adjustment is in error. The daily adjustment for this time-step was set to 10 cfs, the value for August 1933.

CVP M&I Demands

Reclamation M&I contractor demands upstream from the Delta have not been adequately represented in CalSim II until Reclamation updated the model in 2012. A more accurate representation of CVP M&I demands, developed in 2012, was incorporated into the model for this effort.

Yuba Accord Water Transfer

In CalSim, Yuba Accord Water Transfers are limited to releases from New Bullards Bar Reservoir. The release is picked up at Banks Pumping Plant or stored in Oroville and Shasta for later release. The additional release from New Bullards Bar is represented in CalSim through an inflow arc. The subsequent refill of New Bullards Bar is represented in CalSim through a diversion arc. In CalSim II, refill is assumed to always occur in the winter following the transfer. However, in the SWP DRR model, there were a few years in which no transfers took place but refill still occurred in the following winter. This was fixed in the updated baseline by capping refill to the previous summer's total transfer.

Los Vaqueros Reservoir

Expansion of Los Vaqueros Reservoir was completed in 2012. Storage capacity was increased from 103 TAF to 160 TAF. In DWR's BDCP studies, Los Vaqueros capacity was set to 103 TAF. The independent modeling increases Los Vaqueros capacity to 160 TAF.

3.2 Changes to BDCP Operations

San Luis Reservoir Rule-Curve Logic Change

In the independent modeling, San Luis rule-curve logic was refined for both SWP and CVP operations. San Luis rule-curve is used to maintain an appropriate balance between San Luis Reservoir storage and North of Delta reservoirs. The key considerations in formulating rule-curve are as follows:

- Ensure that sufficient water is available in San Luis Reservoir to meet contract allocations when exports alone are insufficient due to various operational constraints.
- Minimize San Luis Reservoir carryover storage to low point criteria (both CVP and SWP) and Article 56 carryover (only SWP). The basic premise is to maintain Reservoir San Luis storage no higher than necessary to satisfy south of Delta obligations to avoid excessive drawdown of upstream storage.

In DWR's BDCP studies, there were significant shortages in Table A and Article 56 deliveries because of an improper balance between upstream and San Luis Reservoir storage. The updated SWP rule-curve logic reduces these shortages but does not eliminate them. Also, the updated CVP rule-curve logic allows for higher CVP allocations without increasing risk of shorting SOD contractors.

Upstream Storage Release to Fill San Luis Reservoir Above Needed Supply

In the BDCP NAA and the independent modeling FNA, the model has a priority to release excess stored water that will likely be released for flood control purposes from Shasta and Folsom storage for export at Jones Pumping Plant to storage in San Luis Reservoir in the late summer and early fall months. The purpose was to get a head start on filling San Luis Reservoir for the coming water year if there is a high likelihood of Shasta or Folsom spilling. This was an assumed CVP/SWP adaptation to the export reductions in the winter and spring months due to the salmon and smelt biological opinions. However, with the NDD facility in Alt 4, winter and spring export restrictions impact CVP exports much less and there is no longer a reason to impose this risk on upstream storage. As such, the weights, or prioritizations, of storage in Shasta and Folsom were raised so that excess water would

not be released specifically to increase CVP San Luis storage Reservoir above rule-curve. This was changed in Alt 4 and not the FNA to better reflect how the system may operate under these different conditions.

Delivery allocation adjustment for CVP SOD Ag service and M&I contractors

CVP SOD Ag service and M&I allocations are limited by both systemwide water supply (storage plus inflow forecasts) and Delta export constraints; whereas similar CVP NOD allocations are dependent solely on water supply. This frequently results in SOD water service contractors receiving a lower contract year allocation than NOD water service contractors, especially under the Biological Opinion export restrictions. However, with the NDD facility operations as proposed under Alt 4 H3, the CVP can largely bypass these Delta export restrictions, and the export capacity constraint on CVP SOD allocations was determined to be overly conservative. Therefore, the export capacity component of CVP SOD allocations was removed in the BDCP Alternative and both SOD and NOD CVP allocations are equal and based only on water supply.

Folsom/Shasta Balance

CVP operations were refined in the BDCP Alternative to provide maximum water supply benefits to CVP contractors while protecting Trinity, Shasta, and Folsom carryover storage in the drier years. As a whole, this was accomplished with refinements to allocation logic and San Luis rule-curve. However, in initial study runs, an imbalance between Folsom and Shasta was created; while there was a total positive impact to upstream storage in dry years, there was a negative impact to Folsom storage. This was resolved by inserting Folsom protections in the Shasta-Folsom balancing logic. With these protections, the positive carryover impacts were distributed to Trinity, Shasta, and Folsom.

North Delta Diversion Bypass Criteria

The daily disaggregation method for implementing NDD bypass criteria as implemented in DWR's BDCP model was left mostly intact for the updated BDCP studies. However, there were modifications to properly fit the bypass criteria implementation within the latest CalSim operations formulation. Modifications are as follows:

1. No NDD operations occur in cycles 6 through 9 so that Delta operations and constraints can be fully assessed without NDD interference.
2. Cycles 10 and 11 (Daily 1 and Daily 2 respectively) were added to determine NDD operations given various operational constraints including the NDD bypass criteria.
3. From July to October, bypass criteria are based on monthly average operations (no daily disaggregation). Given the controlled reservoir releases at this time and the constant bypass criteria (5,000 cfs from July to September and 7,000 cfs in October), this was determined to be a reasonable assumption. This also simplified coordination of DCC gate operations with NDD in October which will be discussed later.
4. When warranted by conditions in cycle Daily 1 (cycle 10), the bypass criteria in May and June were allowed to be modeled on a monthly average basis in cycle Daily 2 (cycle 11). This allowed a reduction in the number of cycles necessary to determine the fully allowed diversion under the bypass criteria when the Delta was in balance and additional upstream releases were made to support diversions from the North Delta.

Delta Cross Channel Gate Reoperation in October

The BDCP Alt 4 results in significantly more October surplus Delta outflow as compared to the baseline. The cause of this Delta surplus at a time when the Delta is frequently in balance is a combination of proposed through-Delta export constraints (OMR flow criteria and no through-Delta exports during the San Joaquin River October pulse period), Rio Vista flow requirements, and DCC gate operations. In DWR's BDCP studies, it was assumed that the

DCC gates would be open for the entire month of October thereby requiring much higher Sacramento River flows at Hood in order to meet the Rio Vista flow requirement than if the DCC gates were closed. Whereas in the independent BDCP modeling it was assumed that the DCC gates were closed for a number of days during the month such that the 7,000 cfs NDD bypass criteria would be sufficient to meet the weekly average Rio Vista flow requirements. The intent was to minimize surplus Delta outflow while meeting Delta salinity standards and maintaining enough bypass flow to use the NDD facility for SOD exports. This is an approximation of what is likely to occur in real-time operations under similar circumstances. Further gate closures may be possible as salinity standards allow if operators decide to preserve upstream storage at the expense of NDD diversions. This type of operation would require additional model refinements.

Wilkins Slough minimum flow requirement


Currently in CalSim II, relaxation of the Wilkins Slough minimum flow requirement is tied to CVP NOD Ag Service Contractor allocations. This does not reflect actual operations criteria where relaxation of the flow requirement is dependent solely on storage conditions at Shasta. From the comparative analysis perspective of our CalSim planning studies, this introduces a potential problem: changes in CVP NOD Ag Service allocations can result in unrealistic changes in required flow at Wilkins Slough, and such changes in Wilkins Slough required flow can result in unrealistic impacts to Shasta storage. To bypass this problem, we assumed that the required flow at Wilkins Slough in the alternative was equal to the baseline.

3.3 Alternative 4 Modeling results

Analysis for this effort was focused on BDCP Alt 4 with existing spring and fall X2 requirements, which corresponds to “Alternative 4 H3” in the Decisions Tree. This modeling is performed without climate change, and includes refined operating criteria for the NDD, CVP and SWP reservoirs, DCC gate closures, and water supply allocations. This modeling includes all Project features that are included in Alt 4 in the BDCP modeling. The Project features are displayed in Figure 39 and summarized as:

- NDD capacity of 9,000 cfs
- Bypass flow requirements for operation of the NDD
- Additional positive OMR flow requirements
- No San Joaquin River I/E ratio
- Changed location for Emmaton water quality standard in SWRCB D-1641
- Additional Sacramento River flow requirement at Rio Vista
- 25,000 acres of additional tidal habitat
- Notched Fremont Weir

Figure 39. Alt 4 Features




For the purpose of describing results of the independent modeling, the revised Future No Action model scenario is labeled “FNA” and the revised BDCP Alt 4 scenario is labeled “Alt 4”.

CVP/SWP Delta Exports

Average annual exports at Jones pumping plant are about 170 TAF higher in the Alt 4 Scenario compared to the FNA scenario, as seen in Figure 40. Increases generally occur from January through June when Old & Middle River (OMR) criteria limit use of Jones PP in the FNA Scenario. Decreases occur in July in drier year types because the increased ability to convey water in spring months reduces the need to convey water stored in upstream reservoirs in July. Reductions in Jones export in October are partially a function of increases in OMR flow requirements.

Figure 40. Change in Delta Exports at Jones Alt 4 minus FNA



Similar to export at Jones, Banks exports are generally higher from January through June because use of NDD allows pumping that is not possible in the FNA Scenario, as seen in Figure 41. Banks exports are increased during summer months of wetter year types. This is due to earlier wheeling for CVP Cross Valley Canal contractors (without NDD Banks capacity isn't typically available until Fall in wet years) and wheeling of CVP water through Joint Point of Diversion (JPOD). CVP export at Banks is displayed in **Figure 42**. In wetter years, upstream CVP reservoirs hold more water than can be exported at Jones pumping plant, this water is typically spilled in the FNA scenario. CVP water stored in upstream reservoirs can be released in July, August, and September to support south of Delta beneficial use of water through use of JPOD in Alt 4.

Figure 41. Change in Delta Exports at Banks Alt 4 minus FNA





Figure 42. Change in CVP Delta Exports at Banks Alt 4 minus FNA



Changes in total, South Delta, and North Delta exports are displayed in Figure 43. Average annual increase in total Delta exports is about 750 TAF, the increases primarily occur in wetter year types with lesser increases in dryer years. South Delta export decreases about 2.53 MAF in Alt 4 relative to the FNA. Export through the NDD is 3.28 MAF in Alt 4, about 58% of total exports are diverted from the North Delta.

Figure 43. Change in Conveyance Source of Exports (Alt 4 minus FNA)





Figure 44 contains modeling results from Alt 4 for July, August, and September that plot NDD against SDD (Through Delta Export). There are many occasions when SDD are 3,000 cfs, which is due to criteria specifying that SDD during this time period need to be at least 3,000 cfs prior to diverting at the NDD facility. Although there are about six occurrences in July and three in August where the model did not satisfy this criterion, this issue has not yet been addressed for this modeling effort.


Figure 44. Alt 4 North Delta Diversion Versus South Delta Diversion for July, August, and September



Delta Outflow

Figure 45 contains annual and monthly average changes in Delta outflow by water year type, average annual Delta outflow decreases about 760 TAF in the Alt 4 Scenario relative to the FNA Scenario. The decrease is primarily due to increases in Delta exports, which are about 750 TAF on average. Larger decreases generally occur in January through May when exports are constrained in the FNA Scenario and in the Alt 4 Scenario the NDD can be used to export water. Delta outflow increases in October due to the combination of additional OMR flow requirements that restrict exports and Sacramento River flow requirements at Rio Vista. The additional surplus Delta outflow in Alt 4 was minimized through coordination of the Delta Cross Channel Gate operations with the Rio Vista flow requirements and North Delta Diversion bypass requirements.

Figure 45. Changes in Delta Outflow (Alt 4 minus FNA)



Carryover Storage

Figure 46, Figure 47, Figure 48, and Figure 49 contain exceedance charts for carryover storage and average monthly changes in storage by Sacramento Valley Water Year Type for CVP and SWP upstream reservoirs. CVP/SWP reservoirs tend to be higher in the Alt 4 Scenario relative to the FNA on an average basis. Generally, CVP/SWP reservoirs are higher in storage in dryer year types and can be lower in wetter year types.

Ability to convey stored water from upstream CVP/SWP reservoirs to south of Delta water users is increased in Alt 4 relative to the FNA. Therefore, when upstream reservoirs are at higher storage levels more water is released to satisfy south of Delta water demands. This is the primary reason Shasta, Oroville, and Folsom tend to be lower during summer months of wetter years.

Currently, and in the FNA Scenario, the CVP and SWP ability to export natural flow, or unstored water, is constrained due to SWRCB D-1641 and requirements in the salmon and smelt biological opinions. With the greater ability to export unstored water during winter and spring months in the Alt 4 Scenario, compared to FNA, there is generally a reduced reliance on stored water to satisfy south of Delta demands. The increased ability to export unstored water allows the CVP and SWP to maintain higher storage levels in upstream reservoirs during dryer year types while still maintaining south of Delta deliveries. Carryover storage in the Alt 4 Scenario tends to be higher than the FNA Scenario at lower storage levels, and Alt 4 storage is lower in wetter years when storage levels are higher. In the wettest of years there is enough water in the system that both scenarios have similar carryover storage conditions.

Figure 46. Trinity Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type




Figure 47. Shasta Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type




Figure 48. Oroville Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type





Figure 49. Folsom Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type



San Luis Reservoir Operations

As seen in Figure 50 and Figure 51 below, both CVP and SWP portions of San Luis Reservoir storage fills more regularly in the Alt 4 Scenario. As described earlier in this document, low point in both CVP and SWP San Luis Reservoir is managed to satisfy water supply obligations the model makes during the spring of each year. This is a complex balance involving available upstream storage, available conveyance capacity, delivery allocations, and south of Delta demand patterns. Considering this myriad of variables, there are times when low point in San Luis Reservoir is higher in the Alt 4 Scenario than the FNA Scenario and times when the opposite is true.

Figure 50. SWP San Luis





Figure 51. CVP San Luis



CVP Water Supply

As can be seen in Table 5, the independent modeling analysis shows an average increase of approximately 262 TAF of delivery accruing to CVP customers in the Alt 4 Scenario relative to the FNA Scenario, mostly occurring to CVP SOD agricultural customers. Delivery increases are greater in wetter year types with lower increases in dryer years. Figure 52 contains exceedance probability plots for CVP water service contractor deliveries and allocations. Changes in Sacramento River Settlement and San Joaquin River Exchange Contractor deliveries do not occur in the modeling analysis and are not an anticipated benefit of the BDCP. Although modeling demonstrates minor changes to NOD CVP service contractors, this increase is not an anticipated benefit of the BDCP.

Table 5. CVP Delivery Summary


Average Annual CVP deliveries by Water Year Type FNA (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	220	882	852	214	116	87	273	1860	2380	2306
W	327	1408	875	241	135	90	280	1856	2515	2881
AN	284	999	802	221	113	83	258	1716	2304	2341
BN	206	725	875	217	111	90	281	1900	2413	2176
D	138	569	864	195	106	88	277	1896	2317	2000
C	43	202	741	157	87	71	234	1754	2025	1447

Difference: Alt 4 minus FNA (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	2	251	0	0	9	0	0	0	2	260
W	0	305	0	0	10	0	1	0	0	316
AN	10	492	0	1	14	1	0	-2	10	504
BN	12	354	0	5	16	0	-2	1	19	366
D	-10	67	0	-4	4	1	0	-1	-15	72
C	2	27	0	2	2	1	0	-1	4	29

Figure 52. CVP Water Supply Delivery and Allocation



SWP Water Supply


The independent analysis shows an increase in average annual SWP SOD deliveries of approximately 450 TAF, but a reduction in critical year deliveries of approximately 116 TAF. Annual average Article 21 deliveries increase by about 100 TAF and Article 56 increases by about 18 TAF. Figure 53 contains exceedance probability plots for SWP SOD deliveries for the FNA and Alt 4 Scenarios, each of these plots show increases in higher delivery years. Although Table A deliveries increase in 65% of years, there are decreases in 35% of the dryer years (see Table 6).

Table 6. SWP Delivery Summary

FNA				
	Table A	Art. 21	Art. 56	Total
All Years	2426	64	90	2580
W	3221	98	121	3440
AN	2628	86	81	2794
BN	2527	82	95	2703
D	1809	14	70	1893
C	1105	17	48	1170

Difference Alt4 minus FNA				
	Table A	Art. 21	Art. 56	Total
All Years	328	102	18	448
W	525	220	14	759
AN	636	98	-1	733
BN	565	50	31	647
D	-63	41	27	6
C	-124	-8	16	-116

Figure 53. SWP Delivery for Alt 4 and FNA



4 COMPARING INDEPENDENT MODELING AND BDCP MODELING


The independent modeling effort originally stemmed from reviews of DWR's BDCP modeling where we found that BDCP modeling does not provide adequate information to determine how BDCP may affect the system. Based on the premise that the independent modeling portrays a more accurate characterization of how the CVP/SWP system may operate under Alt 4, this comparison is meant to demonstrate the differences between results of a more accurate analysis and BDCP modeling. Differences in results between these modeling efforts are believed to provide insight regarding how effects that BDCP will have on the actual CVP/SWP system differ from modeling used to support the Draft EIRS.

Although thorough comparisons of modeling were performed, only key differences are illustrated for the purpose of this comparison.

Delta Exports


Figure 54 displays changes in the Delta exports for the BDCP modeling (Alt 4-ELT minus NAA-ELT) and for the independent modeling (Alt 4 minus FNA). Independent modeling analysis shows about 200 TAF greater increases in exports than the BDCP modeling. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. This difference is also attributable to more realistic reservoir operations, more efficient DCC gate operations, changes in water supply allocation logic, and more efficient operation of the NDD.

Figure 54. Result Difference: Delta Exports




Average annual SDD are decreased by about 460 TAF in the independent analysis compared to the BDCP modeling. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. These fixes prevent "artificial" bypass criteria from limiting use of the NDD beyond what is intended in the BDCP project description. This difference is also attributable to more efficient DCC gate operations and more efficient operation of the NDD. Figure 55 demonstrates the difference between the BDCP and independent analysis, where SDD decrease by 2.07 MAF in the BDCP analysis and by 2.53 MAF in the independent analysis.

Figure 55. Result Difference: South Delta Diversion



Use of the NDD is 680 TAF greater in the independent analysis relative to the BDCP analysis. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. These fixes prevent “artificial” bypass criteria from limiting use of the NDD beyond what is described in the BDCP project description. Figure 56 compares average annual NDD in the BDCP to the independent analysis.


Figure 56. Result Difference: North Delta Diversion



Delta Outflow

Total Delta exports in the independent analysis are about 200 TAF greater than the BDCP modeling analysis with a corresponding decrease in Delta outflow in the independent analysis of about 200 TAF. Figure 57 compares average annual changes in Delta outflow between the independent analysis and BDCP modeling, BDCP modeling shows a decrease of about 567 TAF and the independent analysis shows a decrease of about 759 TAF.

Figure 57. Result Difference: Net Delta Outflow



Reservoir Storage

Reservoir operating rules for Alt4 in the BDCP EIRS modeling are changed relative to the NAA. In the BDCP EIRS modeling of Alt 4 rules are set to releases more water from upstream reservoirs to San Luis Reservoir from late winter through July, reduce releases in August, and then minimize releases to drive San Luis Reservoir to dead pool from September through December. This operation is inconsistent with actual operations and causes reductions in upstream storage from May through August. Figure 58 and Figure 59 contain exceedance probability plots of carryover storage and average monthly changes in storage by water year type for Shasta and Folsom for the BDCP and independent modeling. Although carryover storage for Alt 4 and the NAA is similar in the BDCP EIRS modeling, there is drawdown from June through August that may cause impacts to cold water pool management. In the independent modeling upstream reservoirs are drawn down more in years when storage is available while dryer year storage is maintained at higher levels, this is illustrated in the carryover plots for Shasta and Folsom in Figure 58 and Figure 59.

Figure 58. Result Difference: Shasta Storage






Figure 59. Result Difference: Folsom Storage



North Delta Diversions

Independent modeling shows greater NDD during July and other months because the BDCP EIRS modeling includes artificially high Sacramento River bypass flow requirements. Figure 60 contains exceedance probability plots of Sacramento River required bypass, Sacramento River bypass flow, NDD, and excess Sacramento River flow to the Delta. As can be seen in Figure 60, bypass flow is always above the bypass requirement. The BDCP version of CalSim sets a requirement for Sacramento River inflow to the Delta that the independent modeling does not need in order to satisfy Delta requirements, therefore the NDD is higher in the independent modeling.

Figure 60. NDD, and Sacramento River Flow



Delta flows below the NDD facility


Figure 61 contains monthly exceedance probability plots for Sacramento River below the NDD for the following scenarios: 1) BDCP NAA-ELT, 2) BDCP Alt 4-ELT, 3) independent modeling FNA, and 4) independent modeling Alt 4. The most significant differences in flow changes occur in October, July, August, and September. Changes in Sacramento River flow entering the Delta are a key indicator of changes in interior Delta flows, water levels, and water quality.

For the month of October the independent modeling shows flow below the NDD to be about 2,000 cfs lower than the BDCP modeling. The difference in this month is largely due to reoperation (closure) of the cross channel gate to lessen the amount of Sacramento River flow at Hood necessary to maintain Rio Vista flow requirements downstream of the cross channel gates.

The most substantial difference between the BDCP and independent modeling occurs in July and August. The differences in these two months are primarily attributable to model fixes that have occurred since the BDCP modeling was performed. In the independent modeling, July flows are reduced on average about 7,500 cfs while BDCP shows a reduction of about 3,300 cfs. In the independent modeling August flows are reduced on average about 5,900 cfs while BDCP shows a reduction of about 3,900 cfs.

In the independent modeling September flows are reduced by about 6,100 cfs while BDCP modeling shows a reduction of about 5,300 cfs. The independent modeling shows Sacramento River flow entering the Delta to be about 7,000 cfs 50% of the time, BDCP modeling show Sacramento River flow is about 8,000 cfs 50% of the time.


Figure 61. Sacramento River below Hood



Sacramento River water entering the Central Delta

In CalSim, flow through the DCC gate and Georgianna Slough from the Sacramento River into the Central Delta is assumed to be linearly dependent on flow at Hood. There are two linear relationships; one is used when the DCC gates are closed, and the other is used when the DCC gates are open. The 2013 SWP Delivery Reliability Report CalSim II modeling, and therefore our independent modeling, used different linear flow relationships than BDCP. The BDCP and 2013 DRR (and independent) flow relationships for both the open and closed gate conditions are compared in Figure 62. When Sacramento River flow at Hood is in the range from 5,000 cfs to 10,000 cfs the balance between Hood flow, required flow at Rio Vista, and DCC gate operation can affect upstream reservoir operations, SOD exports, and Delta outflow. As shown in Figure 62, given the same flow at Hood and DCC gates closed, the independent analysis will show slightly higher flow into the Central Delta (12% to 17% difference for the Hood flows in the 5,000 cfs to 10,000 cfs range). With DCC gates open the same flow at Hood, the independent analysis will show lower flow into the Central Delta (-15% to -25% difference for the Hood 5,000 cfs to 10,000 cfs range). Figure 63 and Figure 64 show the differences through the DCC and combined flow through the DCC and Georgiana Slough.

Figure 62. Flow through Delta Cross Channel and Georgiana Slough versus Sacramento River Flow at Hood



In addition to the differences in flow equations for portion of Sacramento River entering the interior Delta through the DCC and Georgiana Slough, the DCC gate operations were modified for the month of October. In the independent modeling, the DCC gate is operated to balance the amount of Sacramento River flow needed to meet flow standards at Rio Vista on the Sacramento River and flow needed to meet western Delta water quality. This changed operation often results in DCC gate closures for about 15 days during the month of October. The reduction in flow through the DCC during October can be seen in Figure 64.

Figure 63. Cross Channel Flow





Figure 64. Flow through Delta Cross Channel and Georgiana Slough



Conclusions regarding BDCP effects

1. The amount of water exported (diverted from the Delta) may be about 200 thousand acre-feet (TAF) per year higher than the amount disclosed in the Draft EIRS. This total represents
 - about 40 TAF/yr more water diverted and delivered to the SWP south of Delta contractors, and
 - about 160 TAF/yr more water diverted and delivered to the CVP south of Delta contractors.
2. Our independent analysis using the revised CalSim II model estimates that, under the No Action Alternative (without the BDCP), total average annual exports, for CVP and SWP combined, are estimated to be 4.86 million acre feet (MAF) in a Future No Action (FNA), and 5.61 MAF in the Alt 4 Scenario. BDCP modeling shows an increase in export of about 540 TAF and independent modeling shows an increase of about 750 TAF.
3. Delta outflow would decrease by about 200 TAF/yr compared to the amount indicated in the Draft EIRS.
 - This lesser amount of Delta outflow has the potential to cause greater water quality and supply impacts for in-Delta beneficial uses and additional adverse effects on species. To determine the potential effects of the reduced amount of outflow, additional modeling is needed using tools such as DSM2.
4. Delta diversions are increased once the location of the North Delta intakes is accurately represented.
 - When the NDD location errors are corrected, modeling reveals that the North Delta intakes could divert about 680 TAF/yr more than what was disclosed in the BDCP Draft EIRS and
 - The amount of water diverted at the existing South Delta facilities would be about 460 TAF/yr less than what is projected in the BDCP Draft EIRS.

Caveat Regarding Both BDCP Draft EIRS Modeling and Independent Modeling

Hydrologic modeling of BDCP alternatives using CalSim II has not been refined enough to understand how BDCP may affect CVP and SWP operations and changes in Delta flow dynamics. Better defined operating criteria for project alternatives is needed along with adequate modeling rules to analyze how BDCP may affect water operations. Without a clear understanding of how BDCP may change operations, affects analysis based on this modeling may not produce reliable results and should be revised as improved modeling is developed.