

---

**From:** Hinojosa, Tracy@DWR  
**Sent:** Tuesday, August 26, 2014 2:33 PM  
**To:** Grober, Les@Waterboards  
**Cc:** Stein, Russell@DWR; Rea, Maria@NOAA; [pfujitani@usbr.gov](mailto:pfujitani@usbr.gov); Wilcox, Carl@Wildlife; Wilson, Craig@Waterboards; Castleberry, Dan@fws; [Garwin.Yip@noaa.gov](mailto:Garwin.Yip@noaa.gov); Riddle, Diane@Waterboards; [RMILLIGAN@usbr.gov](mailto:RMILLIGAN@usbr.gov); Pettit, Tracy@DWR; Mizell, James@DWR; [michael\\_chotkowski@fws.gov](mailto:michael_chotkowski@fws.gov); Leahigh, John@DWR; Yamanaka, Dan@DWR; [ekiteck@usbr.gov](mailto:ekiteck@usbr.gov); [rpyaworsky@usbr.gov](mailto:rpyaworsky@usbr.gov)  
**Subject:** Conserved Water Accounting under TUCP Order

Les--

In its May 2, 2014 Order Modifying and Renewing an Order that Approved a Temporary Urgency Change in License and Permit Terms and Conditions Requiring Compliance with the Delta Water Quality Objectives in Response to Drought Conditions, the State Water Resources Control Board (Board) required the Department of Water Resources (DWR) and the U.S. Bureau of Reclamation (Reclamation) to “calculate and maintain a record of the amount of water conserved through the changes authorized by this Order” and to “submit such records on a monthly basis to the State Water Board by the end of the following month.”

In compliance with that requirement, DWR and Reclamation (the Projects) are presenting the attached table showing daily accounting for conserved water under the Order for the month of July, along with the detailed summary below.

The May 2 Order modified the 4,000 cfs Delta Outflow requirement for May and July to 3,000 cfs on a 30-day average and modified the Western Delta agricultural standard compliance point from Emmaton to Threemile Slough. The Order was in effect beginning on July 10 as 14-day outflow values dropped below 4,000 cfs. Emmaton 14-day electrical conductivity (EC) exceeded the 2.78 uS/cm limit for six days between July 18 and 23. DSM2 modeling indicates that increasing daily outflow to 4,000 cfs from July 10 through the end of the month would have kept 14-day EC values at Emmaton below the standard.

By modifying the Delta outflow requirement to 3,000 cfs on a 30-day average and the agricultural standard from Emmaton to Threemile Slough, the Projects conserved approximately 46 TAF in July. In total, the TUCP Order has allowed the Projects to conserve approximately 399 TAF February through July.

If you have any questions or would like more information, please contact Mr. Dan Yamanaka at (916) 574-0456 or Mr. Paul Fujitani at (916) 979-2197.

Thank you!

Tracy Hinojosa  
Regulatory Compliance & Reporting Branch Chief  
SWP Operations Control Office  
☎ 916-574-2333 (office)  
☎ 916-764-7024 (mobile)

JULY date	X2 (0 days at Chipps Island, 0 days at Collinsville; 0 Chipps Island equivalent 30- day outflow under D1641			TUCP in Effect		Daily Combined Exports (cfs)	Emmaton Historical 14- day EC (uS/cm)	Emmaton Modeled 14- Day EC (uS/cm)	Modeled NDOI	Modeled 7- day outflow (cfs)	ESTIMATED Emmaton Savings <sup>1</sup> (cfs)	Modeled Daily Outflow (Actual + Emmaton Savings)	Total $\Delta$ Outflow (cfs)	Water Conserved (TAF)
	Actual Daily Outflow	calculated 7-day outflow	for Emmaton	for Outflow										
7/1/2014	4,000	4,042	5,389			1,865	2,704	2,405	4,042	5,389		4,042	0	0.00
7/2/2014	4,000	3,501	5,129		x	1,917	2,667	2,334	4,000	5,200		4,000	499	0.99
7/3/2014	4,000	3,728	4,860		x	1,912	2,612	2,276	4,000	4,970		4,000	272	0.54
7/4/2014	4,000	3,425	4,479		x	1,907	2,558	2,226	4,000	4,671		4,000	575	1.14
7/5/2014	4,000	3,013	4,044		x	1,914	2,474	2,180	4,000	4,378		4,000	987	1.96
7/6/2014	4,000	2,651	3,651		x	1,920	2,394	2,136	4,000	4,177		4,000	1,349	2.67
7/7/2014	4,000	2,461	3,260		x	1,955	2,346	2,091	4,000	4,006		4,000	1,539	3.05
7/8/2014	4,000	2,667	3,064		x	1,924	2,330	2,046	4,000	4,000		4,000	1,333	2.64
7/9/2014	4,000	2,789	2,962		x	1,929	2,331	2,007	4,000	4,000		4,000	1,211	2.40
7/10/2014	4,000	3,326	2,904		x	1,353	2,375	1,979	4,000	4,000		4,000	674	1.34
7/11/2014	4,000	3,022	2,847		x	1,688	2,433	1,970	4,000	4,000		4,000	978	1.94
7/12/2014	4,000	3,149	2,866		x	1,927	2,500	1,981	4,000	4,000		4,000	851	1.69
7/13/2014	4,000	3,742	3,022		x	1,364	2,578	2,014	4,000	4,000		4,000	258	0.51
7/14/2014	4,000	3,354	3,150		x	1,806	2,637	2,067	4,000	4,000		4,000	646	1.28
7/15/2014	4,000	2,962	3,192		x	2,083	2,655	2,132	4,000	4,000		4,000	1,038	2.06
7/16/2014	4,000	3,754	3,330		x	1,126	2,708	2,202	4,000	4,000		4,000	246	0.49
7/17/2014	4,000	2,600	3,226		x	1,743	2,765	2,276	4,000	4,000		4,000	1,400	2.78
7/18/2014	4,000	2,600	3,166	x	x	1,997	2,817	2,350	4,000	4,000		4,000	1,400	2.78
7/19/2014	4,000	3,623	3,234	x	x	1,219	2,860	2,418	4,000	4,000		4,000	377	0.75
7/20/2014	4,000	3,011	3,129	x	x	1,699	2,903	2,486	4,000	4,000		4,000	989	1.96
7/21/2014	4,000	2,564	3,016	x	x	1,952	2,924	2,552	4,000	4,000		4,000	1,436	2.85
7/22/2014	4,000	3,525	3,097	x	x	1,359	2,920	2,617	4,000	4,000		4,000	475	0.94
7/23/2014	4,000	3,309	3,033	x	x	1,689	2,872	2,680	4,000	4,000		4,000	691	1.37
7/24/2014	4,000	3,723	3,194		x	1,935	2,777	2,738	4,000	4,000		4,000	277	0.55
7/25/2014	4,000	4,775	3,504			1,361	2,676	2,785	4,775	4,111		4,775	0	0.00
7/26/2014	4,000	4,219	3,590			1,691	2,595	2,821	4,219	4,142		4,219	0	0.00
7/27/2014	4,000	3,349	3,638		x	1,983	2,529	2,845	4,000	4,142		4,000	651	1.29
7/28/2014	4,000	3,857	3,823		x	1,304	2,480	2,858	4,000	4,142		4,000	143	0.28
7/29/2014	4,000	3,332	3,795		x	1,710	2,414	2,868	4,000	4,142		4,000	668	1.33
7/30/2014	4,000	3,058	3,759		x	1,941	2,362	2,875	4,000	4,142		4,000	942	1.87
7/31/2014	4,000	2,828	3,631		x	1,871	2,320	2,876	4,000	4,142		4,000	1,172	2.32

Total for July (TAF): 45.77

<sup>1</sup>From results of DSM2 modeling.