

Monterey County Hospitality Association
Water Use Experience of Seven Monterey Peninsula Full Service Hotels
 FYs Ended June 30, 1987 and June 30, 1997

	YE 6-30-87	YE 6-30-97	Increase (Decrease) in Units	Increase (Decrease) in %
Average Units of Water per Occupied Room Night	0.3475	0.1904	-0.1571	-45.2086%
Average Guests per Occupied Room	1.697	1.707	0.01	0.5893%
Average Units of Water per Guest	0.2048	0.1115	-0.0933	-45.5566%
A unit of water is 100 cubic feet, or 748 gallons.				
The water use of these full service hotels is calculated based on total water use as a function of occupancy; water used for community services such as banquets, other community meetings, local resident restaurant activity, etc., is accounted for in these tables.				
Information is from a survey performed by the Monterey County Travel and Tourism Alliance (now styled Monterey County Convention and Visitors Bureau)				

Prepared by Bob McKenzie
 from MCTTA survey data

7/8/08