

**PUBLIC NOTICE FOR
CLEAN WATER ACT 401 WATER QUALITY CERTIFICATION
BEFORE THE STATE WATER RESOURCES CONTROL BOARD**

A request for a water quality certification (certification) under section 401 of the Clean Water Act for the following project was filed with the State Water Resources Control Board (State Water Board). California Code of Regulations, title 23, section 3858 requires the Executive Director of the State Water Board to provide public notice of an application for certification at least twenty-one (21) days before taking certification action on the application. The notice period may be shortened in an emergency.

Written questions and/or comments regarding the application should be directed to Glenn Hoffmann:

By email:

Glenn.Hoffmann@Waterboards.ca.gov

or

By mail:

State Water Resources Control Board
Division of Water Rights – Water Quality Certification Program
Attn: Glenn Hoffmann
P.O. Box 2000
Sacramento, CA 95812-2000

RECEIVED:	May 12, 2023
PROJECT:	Removal and Decommissioning of the Kanaka Powerhouse for the Kanaka Hydroelectric Project (FERC Project No. 7242) License Surrender
APPLICANT:	STS Hydropower, LLC
CONTACT:	Melissa Rondou
COUNTY:	Butte
PUBLIC NOTICE:	May 26, 2023

PROJECT DESCRIPTION: On May 12, 2023, STS Hydroelectric, LLC submitted a request for water quality certification for the Removal and Decommissioning of the Kanaka Powerhouse for the Kanaka Hydroelectric Project (FERC Project No. 7242) License Surrender (Project). The Kanaka Hydroelectric Project was damaged as a result of the Ponderosa Fire and ceased operations in August 2017. The Project includes: (1) removal of the Kanaka Powerhouse and substation structures; (2) capping and abandoning in place the penstock; (3) installing a plug on the wet well; (4) regrading and filling the tailrace; (5) regrading the north stream bank and the powerhouse site; and (6) abandoning-in-place the diversion dam. Once decommissioned, the diversion dam will be owned by a private party and natural stream flows (average flow is approximately 10 cfs) will top the diversion dam.