

Notice of Determination

To:

[X] Office of Planning and Research
For U.S. Mail: Street Address:
P.O. Box 3044 1400 Tenth St.
Sacramento, CA 95812 Sacramento, CA 95814

[X] County Clerk for County of Yuba
Address: 915 8th Street, Suite 101
Marysville, CA 95901

From:

State Water Resources Control Board
Division of Water Rights
1001 I Street, 14th Floor
Sacramento, CA 95814
Contact: Jeffrey Parks
Phone: (916) 341-5319

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 201408078

Project Title: Log Cabin Apron Curtain Repair Project

Project Location (include county): Oregon Creek in Yuba County, California.

Project Description: In November of 2011, during a diving inspection Yuba County Water Agency (YCWA) discovered two small areas of scour on the toe of the Log Cabin Diversion Dam spill apron on the downstream side of the dam. YCWA plans to repair the scour areas by drilling dowels into the existing concrete and stream bed in the scour area and then filling the scour areas with fiber reinforced shotcrete which contains a high silica fume content. A discharge pipe from the upstream Log Cabin Diversion Dam temporary impoundment will be extended approximately 150 feet downstream of the dam to allow an estimated 8 cubic feet per second of streamflow to pass around the construction area. A combination of sandbag barriers upstream of the discharge pipe and sump pumps will dewater the construction area, allowing the work to proceed in dry conditions.

This is to advise that the State Water Board (Responsible Agency) approved the above described project on 10/28/2014 and has made the following determinations regarding the above described project:

- 1. The project [ ] will [X] will not have a significant effect on the environment.
2. [ ] An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
[X] A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [X] were [ ] were not made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [X] was [ ] was not adopted for this project.
5. A statement of Overriding Considerations [ ] was [X] was not adopted for this project.
6. Findings [X] were [ ] were not made pursuant to the provisions of CEQA.

This is to certify that the State Water Resources Control Board (Responsible Agency) has taken discretionary action on this project and has incorporated the determinations made above. The Mitigated Negative Declaration is available to the General Public at: State Water Resources Control Board, Division of Water Rights, 1001 I Street, 14th Floor, Sacramento, CA 95814.

Signature (Public Agency): Thomas Howard Title: Executive Director

Date 10/28/14 Date Received for filing at OPR

Reference Section: 21000-21174, Public Resources Code.

